
BTU Sizing Guide

| Model | DVC-35-SPP | DVC-35-IP | DV-55-SPP | DV-55-IP |
|------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|
| BTU Input | | | | |
| Propane Gas | 35,000 BTU | 35,000 BTU | 55,000 BTU | 55,000 BTU |
| Natural Gas | 35,000 BTU | 35,000 BTU | 55,000 BTU | 55,000 BTU |
| Gas Inlet Size | 1/2" | 1/2" | 1/2" | 1/2" |
| BTU Heating Zone | Heat Coverage Area | | | |
| Zone 3 | 1079 sq. ft. (25' x 25' room) | 1079 sq. ft. (25' x 25' room) | 1750 sq. ft. (42' x 42' room) | 1750 sq. ft. (42' x 42' room) |
| Zone 5 | 648 sq. ft. (25' x 25' room) | 648 sq. ft. (25' x 25' room) | 1050 sq. ft. (32' x 32' room) | 1050 sq. ft. (32' x 32' room) |
| Zone 7 | 463 sq. ft. (22' x 22' room) | 463 sq. ft. (22' x 22' room) | 750 sq. ft. (27' x 27' room) | 750 sq. ft. (27' x 27' room) |
| Zone 9 | 360 sq. ft. (19' x 19' room) | 360 sq. ft. (19' x 19' room) | 583 sq. ft. (24' x 24' room) | 583 sq. ft. (24' x 24' room) |



This chart is to be used as a guide only, to assist you in estimating BTU requirements. Actual results may vary depending on your BTU zone and insulating parameters

BTU zones assume spaces meet the average insulation and windows requirements for your zone.

This sizing chart is based on a 72 Degree temperature. To maintain a higher room temperature, please select the next higher BTU zone.